

K-LITE	INTRUSION PROTECTION IP TEST REPORT	Doc. No. KL/LAB/IPT1303
		Rev. No. 00

Product / EUT Details

Product Name	SUDO MINI – ASY VERTICAL
Product ID	2749
Test Location	K-LITE Testing Laboratory
Report Date	10/05/21
Reference Sl. No.	SUDO MINI – ASY VERTICAL/303/IPT1303

IP-6X (DUST TEST) – Conforming to IEC 60529

Test Equipment	Dust proof Apparatus (Refer figure below)
Test Protection	Solid Foreign Object
Category	2
Dust Used	Talcum Powder
Temperature	Ambient
Test Date	10/05/21
Test Duration	8 Hours – (9:30 am to 5:30 pm)
EUT Condition	Power OFF

Requirement	Results	Remarks
No deposit of dust inside the EUT.	No ingress of dust observed on EUT.	P
P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.		



1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

S.Bh.M.s

Tested by

Balamurugan.S

Jr. Engineer Illumination – OPTIC LAB

A.G.

Reviewed by

Akram Basha.H

TL – OPTIC LAB

Premkumar

Witnessed by

Premkumar. P

Head - QC

Muthukumar

Approved by

Muthukumaran.C.R

Manager - Design

K-LITE	MOISTURE PROTECTION IP TEST REPORT	Doc. No. KL/LAB/IPT1303
		Rev. No. 00

Product / EUT Details


Product Name	SUDO MINI – ASY VERTICAL
Product ID	2749
Test Location	K-LITE Testing Laboratory
Report Date	10/05/21
Reference Sl. No.	SUDO MINI – ASY VERTICAL/303/IPT1303

IP-X5 (JET PROOF TEST) – Conforming to IEC 60529

Test Equipment	Sharadatronic Jet proof/Rainfall test setup (Refer figure below)
Spray	6.3mm nozzle jet
Total water flow rate	12.5 Ltr/min.
Distance from Nozzle to EUT	Within 3mtr.
Test Date	10/05/21
Test Duration	3 Minutes
EUT Condition	Power OFF

Requirement	Results	Remarks
Water projected by a nozzle against the EUT from any direction shall have no harmful effects.	No ingress of water observed on EUT.	P

P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.



- 1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

S. Bal Murugan

Tested by

Balamurugan.S

Jr. Engineer Illumination – OPTIC LAB

Akram Basha

Reviewed by

Akram Basha.H

TL – OPTIC LAB

Premkumar

Witnessed by

Premkumar. P

Head - QC

Muthukumar

Approved by

Muthukumaran.C.R

Manager - Design