

K-LITE	MOISTURE PROTECTION IP TEST REPORT	Doc. No. KL/LAB/IPT1315
		Rev. No. 00

Product / EUT Details

Product Name	SUDO - ASY
Product ID	2743
Test Location	K-LITE Testing Laboratory
Report Date	29/05/21
Reference Sl. No.	SUDO - ASY/315/IPT1315





IP-X5 (JET PROOF TEST) – Conforming to IEC 60529

Test Equipment	Sharadatronic Jet proof/Rainfall test setup (Refer figure below)
Spray	6.3mm nozzle jet
Total water flow rate	12.5 Ltr/min.
Distance from Nozzle to EUT	Within 3mtr.
Test Date	29/05/21
Test Duration	3 Minutes
EUT Condition	Power OFF

Requirement	Results	Remarks
Water projected by a nozzle against the EUT from any direction shall have no harmful effects.	No ingress of water observed on EUT.	P
P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.		



- 1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

 Tested by Kuncham Mohan Rao Jr. Engineer Illumination – OPTIC LAB	 Reviewed by Akram Basha.H TL – OPTIC LAB	 Witnessed by Premkumar. P Head - QC	 Approved by Muthukumaran.C.R Manager - Design
---	--	--	---



K-LITE	INTRUSION PROTECTION IP TEST REPORT	Doc. No. KL/LAB/IPT1315
		Rev. No. 00

Product / EUT Details

Product Name	SUDO - ASY
Product ID	2743
Test Location	K-LITE Testing Laboratory
Report Date	29/05/21
Reference Sl. No.	SUDO - ASY/315/IPT1315

IP-6X (DUST TEST) – Conforming to IEC 60529

Test Equipment	Dust proof Apparatus (Refer figure below)
Test Protection	Solid Foreign Object
Category	2
Dust Used	Talcum Powder
Temperature	Ambient
Test Date	29/05/21
Test Duration	8 Hours – (9:20 am to 5:20 pm)
EUT Condition	Power OFF

Requirement	Results	Remarks
No deposit of dust inside the EUT.	No ingress of dust observed on EUT.	P
P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.		



- 1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

K. Mohan Rao
Tested by

Kuncham Mohan Rao
Jr. Engineer Illumination – OPTIC LAB

AK
Reviewed by

Akram Basha.H
TL – OPTIC LAB

Premkumar
Witnessed by

Premkumar. P
Head - QC

Muthukumar
Approved by

Muthukumaran.C.R
Manager - Design

K-LITE	INTRUSION PROTECTION IP TEST REPORT	Doc. No. KL/LAB/IPT1317
		Rev. No. 00

Product / EUT Details

Product Name	SUDO MINI - ASY
Product ID	2747
Test Location	K-LITE Testing Laboratory
Report Date	01/06/21
Reference Sl. No.	SUDO MINI - ASY/317/IPT1317

IP-6X (DUST TEST) – Conforming to IEC 60529

Test Equipment	Dust proof Apparatus (Refer figure below)
Test Protection	Solid Foreign Object
Category	2
Dust Used	Talcum Powder
Temperature	Ambient
Test Date	01/06/21
Test Duration	8 Hours – (9:20 am to 5:20 pm)
EUT Condition	Power OFF

Requirement	Results	Remarks
No deposit of dust inside the EUT.	No ingress of dust observed on EUT.	P
P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.		



- 1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

K. Mohan Rao
Tested by

Kuncham Mohan Rao
Jr. Engineer Illumination – OPTIC LAB

AG
Reviewed by

Akram Basha.H
TL – OPTIC LAB

Premkumar
Witnessed by

Premkumar. P
Head - QC

Muthukumar
Approved by

Muthukumar.C.R
Manager - Design

Product / EUT Details

Product Name	SUDO MINI - ASY
Product ID	2747
Test Location	K-LITE Testing Laboratory
Report Date	01/06/21
Reference Sl. No.	SUDO MINI - ASY/317/IPT1317

IP-X5 (JET PROOF TEST) – Conforming to IEC 60529

Test Equipment	Sharadatronic Jet proof/Rainfall test setup (Refer figure below)
Spray	6.3mm nozzle jet
Total water flow rate	12.5 Ltr/min.
Distance from Nozzle to EUT	Within 3mtr.
Test Date	01/06/21
Test Duration	3 Minutes
EUT Condition	Power OFF

Requirement	Results	Remarks
Water projected by a nozzle against the EUT from any direction shall have no harmful effects.	No ingress of water observed on EUT.	P
P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.		



- 1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

K. Mohan Rao

Tested by

Kuncham Mohan Rao

Jr. Engineer Illumination – OPTIC LAB

AG

Reviewed by

Akram Basha.H

TL – OPTIC LAB

Premkumar.P

Witnessed by

Premkumar. P

Head - QC

Muthukumar.C.R

Approved by

Muthukumar.C.R

Manager - Design

K-LITE	INTRUSION PROTECTION IP TEST REPORT	Doc. No. KL/LAB/IPT1316
		Rev. No. 00


Product / EUT Details

Product Name	SUDO - ASY
Product ID	2757
Test Location	K-LITE Testing Laboratory
Report Date	31/05/21
Reference Sl. No.	SUDO - ASY/316/IPT1316

IP-6X (DUST TEST) – Conforming to IEC 60529

Test Equipment	Dust proof Apparatus (Refer figure below)
Test Protection	Solid Foreign Object
Category	2
Dust Used	Talcum Powder
Temperature	Ambient
Test Date	31/05/21
Test Duration	8 Hours – (9:20 am to 5:20 pm)
EUT Condition	Power OFF

Requirement	Results	Remarks
No deposit of dust inside the EUT.	No ingress of dust observed on EUT.	P
P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.		



1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

K. Mohan Rao
Tested by

Kuncham Mohan Rao
Jr. Engineer Illumination– OPTIC LAB

Akram Basha
Reviewed by

Akram Basha.H
TL – OPTIC LAB

Premkumar
Witnessed by

Premkumar. P
Head - QC

Muthukumar
Approved by

Muthukumaran.C.R
Manager - Design

K-LITE	MOISTURE PROTECTION IP TEST REPORT	Doc. No. KL/LAB/IPT1316
		Rev. No. 00

Product / EUT Details

Product Name	SUDO - ASY
Product ID	2757
Test Location	K-LITE Testing Laboratory
Report Date	31/05/21
Reference Sl. No.	SUDO - ASY/316/IPT1316





IP-X5 (JET PROOF TEST) – Conforming to IEC 60529

Test Equipment	Sharadatronic Jet proof/Rainfall test setup (Refer figure below)
Spray	6.3mm nozzle jet
Total water flow rate	12.5 Ltr/min.
Distance from Nozzle to EUT	Within 3mtr.
Test Date	31/05/21
Test Duration	3 Minutes
EUT Condition	Power OFF

Requirement	Results	Remarks
Water projected by a nozzle against the EUT from any direction shall have no harmful effects.	No ingress of water observed on EUT.	P
P→ Passed (Meets requirement); F→ Failed (Does not meet requirement); NA→ Limits of Performance Not Applicable.		



- 1.This report refers only to the particular item(s) submitted for testing. The results reported in this report are valid at the time of, and under the stipulated conditions of measurement
2.This report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Director, K-LITE, Chennai-600058

 Tested by Kuncham Mohan Rao Jr. Engineer Illumination– OPTIC LAB	 Reviewed by Akram Basha.H TL – OPTIC LAB	 Witnessed by Premkumar. P Head - QC	 Approved by Muthukumaran.C.R Manager - Design
--	--	--	---